



Product Service

CERTIFICATE

No. Z10 068636 0050 Rev. 00

Holder of Certificate: **Leuze electronic GmbH + Co.KG**

In der Braike 1
73277 Owen/Teck
GERMANY

Certification Mark:



Product: **Safety components**
Emergency-Stop Relay,
Safety Sequential Circuit

Model(s): **MSI-RM2**
MSI-RM2B-01
MSI-RM2B-02

Parameters:

Supply Voltage:	24V AC/DC \pm 20%
Power consumption:	2,1W (AC) / 1,7W (DC)
Output current:	AC-15, 250V: 5A DC-13, 24V: 3A
Operating temperature:	0°C...+50°C
Storage temperature:	-25...+70°C
Protection class:	IP20

Tested according to: 2006/42/EC
EN ISO 13849-1:2015 (Cat 4, PL e)
ISO 13849-1:2015 (Cat. 4, PL e)
EN IEC 61496-1:2020 (Type 4)
IEC 61496-1:2020 (Type 4)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: LO97717T
Valid until: 2026-11-17

Date, 2021-11-19

(Christian Dirmeier)