



Product Service

CERTIFICATE

No. Z10 068636 0049 Rev. 00

Holder of Certificate: **Leuze electronic GmbH + Co.KG**

In der Braike 1
73277 Owen/Teck
GERMANY

Certification Mark:



Product: **Safety components**
Safety switching device

Model(s): **MSI-SR4**
MSI-SR4B-01
MSI-SR4B-02

Parameters: Supply Voltage: 24V AC/DC $\pm 20\%$
Operating temperature: 0°C...+55°C
Storage temperature: -25°C...+70°C
IP code (housing): IP40
IP code (terminals): IP20

Tested according to: 2006/42/EC
EN IEC 61496-1:2020 (Type 4)
IEC 61496-1:2020 (Type 4)
EN 61508-1:2010 (SIL 3)
EN 61508-2:2010 (SIL 3)
IEC 61508-1:2010 (SIL 3)
IEC 61508-2:2010 (SIL 3)
EN ISO 13849-1:2015 (Cat 4, PL e)
ISO 13849-1:2015 (Cat.4, PL e)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 717501361
Valid until: 2026-11-18

Date, 2021-11-19

(Christian Dirmeier)