Leuze

Technical data sheet Optical data transmission

Part no.: 50150861 DDLS 508 120.3 L H W

The Sensor People In der Braike 1, D-73277 Owen/Germany



1/8

changes

Phone: +49 7021 573-0 • Fax: +49 7021 573-199 eng • 2025-04-11

Technical data

Basic data


Basic data	
Series	DDLS 500
Special version	
Special version	Heating
	Integrated laser alignment aid
	Not influenced by reflective surfaces
	Operation of parallel light axes
	Wide angle version
Optical data	
Norking range	100 120,000 mm
Light source	Laser
Transmission frequency	F3
Opening angle	1.6 °
Electrical data	
Performance data	
Supply voltage U _B	18 30 V, DC
Inputs	
Number of digital switching inputs	1 Piece(s)
Outputs	
Number of digital switching outputs	1 Piece(s)
nterface	
Fransmission protocol	CIPsafety
Гуре	EtherNet IP, EtherNet TCP/ IP, PROFINET, PROFIsafe over PROFINET
EtherNet IP	
Function	Process
Address assignment	None
Switch functionality	None
Transmission speed	100 Mbit/s
Ethernet	
Architecture	Transparent
Address assignment	None
Transmission speed	100 Mbit/s
Function	Process
Switch functionality	None
Transmission protocol	TCP/IP
PROFINET	
Function	Process
Transmission protocol	PROFINET IO / RT
	PROFINET IRT
	PPOElsafe
Switch functionality	PROFIsafe
Switch functionality	None
Switch functionality Transmission speed	
	None


Connection 1	0
Type of connection	Connector
Designation on device	POWER
Thread size	M12
Туре	Male
No. of pins	5 -pin
Encoding	A-coded
Connection 2	
Type of connection	Connector
Designation on device	BUS
Thread size	M12
Туре	Female
No. of pins	4 -pin
Encoding	D-coded
Mechanical data	
Dimension (W x H x L)	100 mm x 156 mm x 99.5 mm
Housing material	Metal
Net weight	1,750 g
	.,
Operation and display	
Type of display	Bar graph
	LED
Environmental data	
Ambient temperature, operation	-35 50 °C
Ambient temperature, storage	-35 70 °C
Certifications	
	IP 65
Degree of protection	IP 65 c UL US
Degree of protection Approvals	c UL US
Degree of protection Approvals Test procedure for EMC in accordance	c UL US
Degree of protection Approvals Test procedure for EMC in accordance with standard Test procedure for noise in accordance	c UL US EN 1000-6-4 EN 61000-6-2
Degree of protection Approvals Test procedure for EMC in accordance with standard Test procedure for noise in accordance with standard Test procedure for oscillation in	c UL US EN 1000-6-4 EN 61000-6-2
Degree of protection Approvals Test procedure for EMC in accordance with standard Test procedure for noise in accordance with standard Test procedure for oscillation in accordance with standard	c UL US EN 1000-6-4 EN 61000-6-2 EN 60068-2-64 EN 60068-2-6
Degree of protection Approvals Test procedure for EMC in accordance with standard Test procedure for noise in accordance with standard Test procedure for oscillation in accordance with standard Test procedure for shock in	c UL US EN 1000-6-4 EN 61000-6-2 EN 60068-2-64
Degree of protection Approvals Test procedure for EMC in accordance with standard Test procedure for noise in accordance with standard Test procedure for oscillation in accordance with standard Test procedure for shock in accordance with standard	c UL US EN 1000-6-4 EN 61000-6-2 EN 60068-2-64 EN 60068-2-6
Degree of protection Approvals Test procedure for EMC in accordance with standard Test procedure for noise in accordance with standard Test procedure for oscillation in accordance with standard Test procedure for shock in accordance with standard Classification	c UL US EN 1000-6-4 EN 61000-6-2 EN 60068-2-64 EN 60068-2-6
Degree of protection Approvals Test procedure for EMC in accordance with standard Test procedure for noise in accordance with standard Test procedure for oscillation in accordance with standard Test procedure for shock in accordance with standard Classification Customs tariff number	c UL US EN 1000-6-4 EN 61000-6-2 EN 60068-2-64 EN 60068-2-6 EN 60068-2-27
Degree of protection Approvals Test procedure for EMC in accordance with standard Test procedure for noise in accordance with standard Test procedure for oscillation in accordance with standard Test procedure for shock in accordance with standard Classification Customs tariff number ECLASS 5.1.4	c UL US EN 1000-6-4 EN 61000-6-2 EN 60068-2-64 EN 60068-2-6 EN 60068-2-27
Degree of protection Approvals Test procedure for EMC in accordance with standard Test procedure for noise in accordance with standard Test procedure for oscillation in accordance with standard Test procedure for shock in accordance with standard Classification Customs tariff number ECLASS 5.1.4 ECLASS 8.0	c UL US EN 1000-6-4 EN 61000-6-2 EN 60068-2-64 EN 60068-2-6 EN 60068-2-27 85365019 19039001
Degree of protection Approvals Test procedure for EMC in accordance with standard Test procedure for noise in accordance with standard Test procedure for oscillation in accordance with standard Test procedure for shock in accordance with standard Classification Customs tariff number ECLASS 5.1.4 ECLASS 8.0 ECLASS 9.0	c UL US EN 1000-6-4 EN 61000-6-2 EN 60068-2-64 EN 60068-2-6 EN 60068-2-27 85365019 19039001 19179090
Degree of protection Approvals Test procedure for EMC in accordance with standard Test procedure for noise in accordance with standard Test procedure for oscillation in accordance with standard Test procedure for shock in accordance with standard Classification Customs tariff number ECLASS 5.1.4 ECLASS 5.0 ECLASS 9.0 ECLASS 10.0	c UL US EN 1000-6-4 EN 61000-6-2 EN 60068-2-64 EN 60068-2-6 EN 60068-2-27 85365019 19039001 19179090 19179090
Degree of protection Approvals Test procedure for EMC in accordance with standard Test procedure for noise in accordance with standard Test procedure for oscillation in accordance with standard Test procedure for shock in accordance with standard Classification Customs tariff number ECLASS 5.1.4 ECLASS 5.1.4 ECLASS 9.0 ECLASS 10.0 ECLASS 11.0	c UL US EN 1000-6-4 EN 61000-6-2 EN 60068-2-64 EN 60068-2-6 EN 60068-2-27 85365019 19039001 19179090 19179090 19170506
Degree of protection Approvals Test procedure for EMC in accordance with standard Test procedure for noise in accordance with standard Test procedure for oscillation in accordance with standard Test procedure for shock in accordance with standard Classification Customs tariff number ECLASS 5.1.4 ECLASS 5.1.4 ECLASS 9.0 ECLASS 9.0 ECLASS 10.0 ECLASS 11.0 ECLASS 12.0	c UL US EN 1000-6-4 EN 61000-6-2 EN 60068-2-64 EN 60068-2-6 EN 60068-2-27 85365019 19039001 19179090 19179090 19170506 19170506
Degree of protection Approvals Test procedure for EMC in accordance with standard Test procedure for noise in accordance with standard Test procedure for oscillation in accordance with standard Test procedure for shock in accordance with standard Classification Customs tariff number ECLASS 5.1.4 ECLASS 5.0 ECLASS 9.0 ECLASS 10.0 ECLASS 11.0 ECLASS 12.0 ECLASS 13.0	c UL US EN 1000-6-4 EN 61000-6-2 EN 60068-2-64 EN 60068-2-6 EN 60068-2-27 85365019 19039001 19179090 19179090 19170506 19170506 19170506
Degree of protection Approvals Test procedure for EMC in accordance with standard Test procedure for noise in accordance with standard Test procedure for oscillation in accordance with standard Test procedure for shock in accordance with standard Classification Customs tariff number ECLASS 5.1.4 ECLASS 5.0 ECLASS 9.0 ECLASS 10.0 ECLASS 11.0 ECLASS 12.0 ECLASS 13.0 ECLASS 14.0	c UL US EN 1000-6-4 EN 61000-6-2 EN 60068-2-64 EN 60068-2-6 EN 60068-2-27 85365019 19039001 19179090 19170506 19170506 19170506 19170506 19170506 19170506
Degree of protection Approvals Test procedure for EMC in accordance with standard Test procedure for noise in accordance with standard Test procedure for oscillation in accordance with standard Test procedure for shock in accordance with standard Classification Customs tariff number ECLASS 5.1.4 ECLASS 9.0 ECLASS 9.0 ECLASS 10.0 ECLASS 11.0 ECLASS 12.0 ECLASS 13.0 ECLASS 14.0 ECLASS 15.0	c UL US EN 1000-6-4 EN 61000-6-2 EN 60068-2-64 EN 60068-2-6 EN 60068-2-27 85365019 19039001 19179090 19179090 19170506 19170506 19170506 19170506 19170506 19170506 19170506
Degree of protection Approvals Test procedure for EMC in accordance with standard Test procedure for noise in accordance with standard Test procedure for oscillation in accordance with standard Test procedure for shock in accordance with standard Classification Customs tariff number ECLASS 5.1.4 ECLASS 9.0 ECLASS 9.0 ECLASS 10.0 ECLASS 11.0 ECLASS 12.0 ECLASS 13.0 ECLASS 14.0 ECLASS 15.0 ETIM 5.0	c UL US EN 1000-6-4 EN 61000-6-2 EN 60068-2-64 EN 60068-2-6 EN 60068-2-27 85365019 19039001 19179090 19179090 19170506 19170506 19170506 19170506 19170506 19170506 19170506 19170506 EC000515
Degree of protection Approvals Test procedure for EMC in accordance with standard Test procedure for noise in accordance with standard Test procedure for oscillation in accordance with standard Test procedure for shock in accordance with standard Classification Customs tariff number ECLASS 5.1.4 ECLASS 5.1.4 ECLASS 8.0 ECLASS 9.0 ECLASS 10.0 ECLASS 11.0 ECLASS 12.0 ECLASS 13.0 ECLASS 13.0 ECLASS 14.0 ECLASS 15.0 ETIM 5.0 ETIM 6.0	c UL US EN 1000-6-4 EN 61000-6-2 EN 60068-2-64 EN 60068-2-6 EN 60068-2-27 85365019 19039001 19179090 19170506 19170506 19170506 19170506 19170506 19170506 19170506 19170506 19170506 19170506 EC000515 EC000515
Degree of protection Approvals Test procedure for EMC in accordance with standard Test procedure for noise in accordance with standard Test procedure for oscillation in accordance with standard Test procedure for shock in accordance with standard Classification Customs tariff number ECLASS 5.1.4 ECLASS 5.1.4 ECLASS 9.0 ECLASS 9.0 ECLASS 10.0 ECLASS 11.0 ECLASS 12.0 ECLASS 12.0 ECLASS 14.0 ECLASS 15.0 ETIM 5.0 ETIM 5.0 ETIM 7.0	c UL US EN 1000-6-4 EN 61000-6-2 EN 60068-2-64 EN 60068-2-6 EN 60068-2-27 EN 60068-2-27 EN 60068-2-27 EN 60068-2-27 I 9170506 I 9170506 I 9170506 I 9170506 I 9170506 I 9170506 I 9170506 I 9170506 I 9170506 I 9170506 EC000515 EC000515 EC000515 EC000515
Degree of protection Approvals Test procedure for EMC in accordance with standard Test procedure for noise in accordance with standard Test procedure for oscillation in accordance with standard Test procedure for shock in accordance with standard Classification Customs tariff number ECLASS 5.1.4 ECLASS 5.1.4 ECLASS 8.0 ECLASS 9.0 ECLASS 10.0 ECLASS 10.0 ECLASS 11.0 ECLASS 12.0 ECLASS 13.0 ECLASS 14.0 ECLASS 15.0 ETIM 5.0 ETIM 6.0 ETIM 7.0 ETIM 8.0	c UL US EN 1000-6-4 EN 61000-6-2 EN 60068-2-64 EN 60068-2-6 EN 60068-2-27 85365019 19039001 19179090 19179090 19170506 19170506 19170506 19170506 19170506 19170506 19170506 19170506 19170506 19170506 EC000515 EC000515 EC000515 EC000515 EC000515
Certifications Degree of protection Approvals Test procedure for EMC in accordance with standard Test procedure for noise in accordance with standard Test procedure for oscillation in accordance with standard Classification Customs tariff number ECLASS 5.1.4 ECLASS 9.0 ECLASS 10.0 ECLASS 11.0 ECLASS 11.0 ECLASS 12.0 ECLASS 13.0 ECLASS 14.0 ECLASS 15.0 ETIM 5.0 ETIM 5.0 ETIM 5.0 ETIM 5.0 ETIM 9.0 ETIM 9.0 ETIM 10.0	c UL US EN 1000-6-4 EN 61000-6-2 EN 60068-2-64 EN 60068-2-6 EN 60068-2-27 EN 60068-2-27 EN 60068-2-27 EN 60068-2-27 I 9170506 I 9170506 I 9170506 I 9170506 I 9170506 I 9170506 I 9170506 I 9170506 I 9170506 I 9170506 EC000515 EC000515 EC000515 EC000515


Leuze

Dimensioned drawings

All dimensions in millimeters







A Middleaxis Transmitter

B Center axis of transmitter and receiver

C Center axis of receiver

Leuze

Electrical connection

Connection 1	POWER
Function	Signal IN
	Signal OUT
	Voltage supply
Type of connection	Connector
Thread size	M12
Туре	Male
Material	Metal
No. of pins	5 -pin
Encoding	A-coded

Pin **Pin assignment**

1	VIN	
2	IO1	
3	GND	3
4	102	
5	FE/SHIELD	4

Connection 2


Connection 2	BUS	
Function	BUS IN	
Type of connection	Connector	
Thread size	M12	
Туре	Female	
Material	Metal	
No. of pins	4 -pin	
Encoding	D-coded	

Pin	Pin assignment
1	TD+
2	RD+
3	TD-
4	RD-

Operation and display

LE	ED	Display	Meaning
1	AUT	Off	Operating mode not active
		Green, continuous light	Operating mode "Automatic"
2	MAN	Off	Operating mode not active
		Green, continuous light	Operating mode "Manual"
;	ADJ	Off	Operating mode not active
		Green, continuous light	Operating mode "Adjust"
ŀ	LAS	Off	Operating mode not active
		Green, continuous light	Operating mode "Alignment-laser mounting support"
;	LLC	Off	Operating mode not active
		Green, continuous light	LLC without interruption
		Red, continuous light	LLC interrupted at least once
;	PWR	Off	No supply voltage
		Green, flashing	Device ok, initialization phase
		Green, continuous light	Data transmission active
		Red, flashing	Data transmission interrupted
		Red, continuous light	Device error
,	TMP	Off	Operating temperature OK
		Orange, continuous light	Operating temperature critical





FE 📥

We reserve the right to make technical Leuze electronic GmbH + Co. KG info@leuze.com • www.leuze.com changes The Sensor People In der Braike 1, D-73277 Owen/Germany Phone: +49 7021 573-0 • Fax: +49 7021 573-199 eng • 2025-04-11

Operation and display

Leuze

LED	Display	Meaning
7 TMP	Red, continuous light	Operating temperature exceeded or not met
8 LSR	Off	With function reserve
	Orange, continuous light	Device OK, warning set
9 BUS	Off	Not active for the DDLS 508
10 OLK	Off	Fault
	Green, continuous light	No data transmission
	Orange, continuous light	Data transmission active
11 ERL	Off	Link OK
	Orange, continuous light	Missing link (Ethernet cable connection) on the second device
	Red, continuous light	No cable-connected link to the connected device
12 LINK	Off	No cable-connected link to the connected device
	Green, continuous light	Link OK
	Orange, continuous light	Data transmission active
13 SIGNAL QUALIT	,	Received signal level

Suitable transmitters

 Part no.	Designation	Article	Description
50150862	DDLS 508 120.4 L H W	Optical data transmission	Special version: Not influenced by reflective surfaces, Heating, Integrated laser alignment aid, Operation of parallel light axes, Wide angle version Working range: 100 120,000 mm Transmission frequency: F4 Interface: EtherNet IP, EtherNet TCP/IP, PROFINET Connection: Connector, M12

Suitable receivers

 Part no.	Designation	Article	Description
50150862	DDLS 508 120.4 L H W	Optical data transmission	Special version: Not influenced by reflective surfaces, Heating, Integrated laser alignment aid, Operation of parallel light axes, Wide angle version Working range: 100 120,000 mm Transmission frequency: F4 Interface: EtherNet IP, EtherNet TCP/IP, PROFINET Connection: Connector, M12

Part number code

Part designation: DDLS 5XXX YYY.Z A B CC

DDLS	Optical transceiver for digital data transmission
5XXX	Series 508i: without integrated web server for remote diagnostics 508i: with integrated web server for remote diagnostics 538: without integrated web server for remote diagnostics (EtherCAT) 548i: with integrated web server for remote diagnostics
YYY	Range for data transmission in m
z	Frequency of the transmitter 0: Frequency F0 1: Frequency F1 2: Frequency F2 3: Frequency F3 4: Frequency F4
A	Option L: integrated laser alignment aid (for transmitter/receiver) n/a: standard

Part number code



	Special equipment H: with heating n/a: no special equipment
	Special equipment W: Transmission optics with larger beam spread S3: Optimized for EtherCAT transmission n/a: no special equipment
Note	
A list w	ith all available device types can be found on the Leuze website at www.leuze.com.

Notes

Observe intended use!
 This product is not a safety sensor and is not intended as personnel protection. The product may only be put into operation by competent persons. Only use the product in accordance with its intended use.

For UL applications:
Second Se

ATTENTION! INVISIBLE LASER RADIATION - CLASS 1M LASER PRODUCT
Do not expose users of telescopic optics! The device satisfies the requirements of IEC 60825-1:2007 (EN 60825-1:2007) safety regulations for a product of laser class 1M as well as the U.S. 21 CFR 1040.10 regulations with deviations corresponding to Laser Notice No. 50 from June 24, 2007.
b Do not expose users of telescopic optics! The device satisfies the requirements of IEC 60825-1:2007 (EN 60825-1:2007) safety regulations for a product of laser class 1M as well as the U.S. 21 CFR 1040.10 regulations with deviations corresponding to Laser Notice No. 50 from June 24, 2007.
beam or in the direction of reflecting beams.
 CAUTION! The use of operating and adjusting devices other than those specified here or the carrying out of differing procedures may lead to dangerous exposure to radiation! The use of optical instruments or devices (e.g., magnifying glasses, binoculars) in combination with the device increases the danger of eye damage.
to Observe the applicable statutory and local laser protection regulations.
 ^t The device must not be tampered with and must not be changed in any way. There are no user-serviceable parts inside the device. Repairs must only be performed by Leuze electronic GmbH + Co. KG.

Accessories

Leuze

Connection technology - Connection cables

	Part no.	Designation	Article	Description
W D	50132079	KD U-M12-5A-V1- 050	Connection cable	Connection 1: Connector, M12, Axial, Female, A-coded, 5 -pin Connector, LED: No Connection 2: Open end Shielded: No Cable length: 5.000 mm Sheathing material: PVC
Ŵ	50135074	KS ET-M12-4A-P7- 050	Connection cable	Suitable for interface: Ethernet Connection 1: Connector, M12, Axial, Male, D-coded, 4 -pin Connector, LED: No Connection 2: Open end Shielded: Yes Cable length: 5.000 mm Sheathing material: PUR

Connection technology - Interconnection cables

	Part no.	Designation	Article	Description
	50137078	KSS ET-M12-4A- M12-4A-P7-050	Interconnection cable	Suitable for interface: Ethernet Connection 1: Connector, M12, Axial, Male, D-coded, 4 -pin Connection 2: Connector, M12, Axial, Male, D-coded, 4 -pin Shielded: Yes Cable length: 5,000 mm Sheathing material: PUR
	50135081	KSS ET-M12-4A- RJ45-A-P7-050	Interconnection cable	Suitable for interface: Ethernet Connection 1: Connector, M12, Axial, Male, D-coded, 4 -pin Connection 2: RJ45 Shielded: Yes Cable length: 5,000 mm Sheathing material: PUR

Connection technology - Connectors

	Part no.	Designation	Article	Description
-	50020501	KD 095-5A	Connector	Connection: Connector, M12, Axial, Female, A-coded, 5 -pin
	50112155	S-M12A-ET	Connector	Suitable for interface: Ethernet Connection: Connector, M12, Axial, Male, D-coded, 4 -pin

Accessories

Leuze

Services

 Part no.	Designation	Article	Description
S981001	CS10-S-110	Start-up support	Details: Performed at location of customer's choosing, duration: max. 10 hours. Conditions: Devices and connection cables are already mounted, price not including travel costs and, if applicable, accommodation expenses.
S981005	CS10-T-110	Product training	Details: Location and content to be agreed upon, duration: max. 10 hours. Conditions: Price not including travel costs and, if applicable, accommodation expenses.

	Note
6	A list with all available accessories can be found on the Leuze website in the Download tab of the article detailed page.