



C E R T I F I C A T E

No. Z10 09 12 22795 091

Holder of Certificate: **Leuze electronic GmbH + Co. KG**
Liebigstrasse 4
82256 Fürstfeldbruck
GERMANY

Factory(ies): 22795

Certification Mark:



Product: **Electro-Sensitive Protective Equipment
Type 3**

Model(s): **AS-i Safetybus Interface
AS-i Interface for Rotoscan RS4**

Parameters:
Power supply: 24VDC +20% / -30%
Operating temperature: 0°C to +50°C
Protection class: IP65

Tested according to:
2006/42/EC Machinery Directive
IEC 61508:1998 part 1,3,4 (SIL 2)
IEC 61508-2:2000 (SIL 2)
EN ISO 13849-1:2008 (Cat.3 PL d)
DIN EN 61496-1:2009
EN 61000-6-3:2007
IEC 61496-3:2008
EN 60204-1:2006 (as applicable)
EN 50178:1997
EN 55022:2006

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 70019112

Valid until: 2014-12-29

Date, 2010-01-20


(Günter Greil)

Page 1 of 1

